



Engineering Specification

Division 22 - PLUMBING

22 11 23.13 - DOMESTIC-WATER PACKAGED BOOSTER PUMPS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Vertical, multistage, centrifugal pump booster package shall be a SiBooster EXCEL booster as manufactured by Wilo USA.
- B. Furnish and install a variable speed, verticalmultistage, centrifugal booster pumping package, with a capacity as indicated in the plans.

1.02 RELATED SECTIONS

- A. 23 21 23 Hydronic Pumps.
- B. 23 22 23.13 Electric-Driven Steam Condensate Pumps.
- C. 23 53 13 Boiler Feedwater Pumps.

1.03 REFERENCES

- A. NSF NSF International
- B. HI Hydraulic Institute
- C. UL Underwriters Laboratories
- D. NEC National Electrical Code
- E. ANSI American National Standards Institute
- F. AISI American Iron and Steel Institute
- G. ISO International Standards Organization
- H. NEMA National Electrical Manufacturers Association
- I. VFD Variable Frequency Drive
- J. ODP Open Drip Proof
- K. TEFC Totally Enclosed Fan Cooled

1.04 SUBMITTALS

- A. Submittal data sheet(s).
- B. Dimensional print(s).
- C. Wiring diagram(s).
- D. Installation, operation, and maintenance manual.

1.05 QUALITY ASSURANCE

- A. The complete packaged pumping system shall be NSF61 Annex G listed for drinking water and low lead requirements.
- B. The complete packaged pumping systems shall be UL QCZJ listed for "packaged pumping systems".
- All wetted surfaces shall be made of corrosionresistant material.
- D. Water temperature range for the booster package shall be rated for -22°F to 248°F

- E. Ambient temperature range for the booster package shall be rated for 5°F 104°F.
- F. Booster pressure rating shall be 232 or 363 PSI depending on number of pump stages.
- G. The pumping package shall be hydrostatically tested prior to shipment.
- H. High efficiency drive (HED) control interface and electronic communicated motor (ECM) shall produce motor efficiencies greater than, or equal to, IE5 (NEMA MG1 TABLE 12-12) motor efficiency standards.

1.06 WARRANTY

- A. Provide manufacturer's standard warranty against defects in materials and workmanship
 - Warranty Period: SiBooster EXCEL Boosters shall be free of defects in materials and workmanship for a period of two (2) years from date of installation; not to exceed 6 months from date of purchase.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Subject to compliance with these specifications, the following manufacturers shall be acceptable:
 - 1. Wilo- SiBooster EXCEL series boosters as manufactured by Wilo.
 - 2. Pre-approved equal.
- B. The packaged pumping system shall be a standard product of a single pump manufacturer. The entire pump system including pumps and pump logic controller, shall be designed, built, and tested by the same manufacturer.

2.02 COMPONENTS

A. PUMPS

- 1. Shall be of vertical, In-Line, multistage design.
- 2. Shall be ANSI/NSF 61 Annex G listed for drinking water and low lead requirements.
- 3. Pump housings:
 - a. Shall be constructed of AISI304 stainless steel with 300 class ANSI flanges.
 - b. Shall be furnished with a carbon and polyphenylene sulfide (PPS) wear ring.

Division 22 - PLUMBING

22 11 23.13 - DOMESTIC-WATER PACKAGED BOOSTER PUMPS

c. Shall be equipped with drain and vent ports with ability to accommodate a bypass.

2.03 COMPONENTS - Continued

- 4. Shall be equipped with an AISI304, AISI318 LN, or AISI431 stainless steel shaft depending on number of Impeller stages and flowrate.
- 5. Shall have lifting lugs to facilitate pump installation or extraction from packaging.
- 6. Shall have a coupling guard in AISI316L stainless steel with Wilo design for better shaft protection.
- 7. Shall allow for easy access to the coupler, spacer and seal cartridge assembly.
- 8. Shall allow for removal/replacement of seal cartridge without removing motor at any horse power.
- 9. Seal cartridge assemblies shall have the ability to be disassembled and replace the mechanical seal without having to replace the entire X-cartridge assembly.
- 10. Mechanical seal:
 - a. Sleeve shall be AISI316L.
 - b. Springs and clips shall be AISI304 stainless steel.
 - c. Inserts shall be constructed of FPDM.
- 11. Impellers shall be constructed of AISI304L stainless steel and 100% laser-welded 2D/3D blades shall be sandblasted prior to shipment.

B. MOTORS

- Shall be a Wilo developed, electrically commutated, synchronous permanent magnet, super premium motor.
- 2. Shall have a protection class of IP52.
- 3. Shall produce motor efficiencies equal to IE5 and NEMA MG1 TABLE 12-12 motor efficiency standards.

C. PUMP INVERTER INTERFACE

- Shall allow for quick access to the main parameters using LCD display and Wilo GREEN BUTTON.
- 2. Shall have two configurations:

- a. Standard control.b. Expert control.
- 3. Shall allow for speed reduction turndown of up to 70%.
- 4. Shall be UL 508C compliant and listed.

D. CONTROL PANEL

- 1. Shall meet the requirements of UL508A; Standard for Industrial Control Equipment.
- 2. Shall be rated as a NEMA 12 enclosure with a fan, CFM rated for heat sink requirements of VFDs (Variable Frequency Drive).
- 3. Shall have labeled wires and terminal block for easy reference to the wiring diagram.
- 4. Motor protector circuits sized for motor amperage.
- 5. Through the door disconnect with selector handle and lockout.

E. PROGRAMABLE LOGIC CONTROLLER

- 1. Shall have a 7" LED Color Touchscreen.
- 2. Shall have a display resolution of 800 x 480 pixels.
- Shall indicate on the display, per the Pump Icon, whether or not each pump is either Green=Running, Red=Faulted, No Color=Off.
- 4. Shall be programmed for lead/lag or duty/standby operation.
- 5. Shall provide off/hand/auto function. Hand operation shall be password protected.
- Shall display pump hours, suction PSI, discharge PSI, pump frequencies, total Kwh for system, and current Kwh per pump.
- 7. Shall be able to modify the discharge pressure setting through password protected screen.
- 8. Shall have a low pressure cut out.
- 9. Shall have pipe burst protection.
- Shall be able to be able to flash the PLC program by means of a Micro-SD card via Micro-SD port.
- 11. Shall have a RJ45 Ethernet port capable of transmitting data 10/100Mbps using a Cat 5 cable.
- 12. Shall have a 2.0 USB port available for communication.

Division 22 - PLUMBING

22 11 23.13 - DOMESTIC-WATER PACKAGED BOOSTER PUMPS

- 13. Shall have onboard Modbus Protocol. Two ports available; one for communication to the VFD and one open for the building management system.
- 14. Shall have the following I/O:
 - a. Number of digital inputs: 18
 - b. Number of digital outputs: 17
 - c. Number of analog inputs: 9
 - d. Number of analog outputs: 2
- 15. Shall be programmed for lead/lag operation.
- 16. Shall use a coin-type 3v, lithium battery, CR2450.
- 17. Shall have a have the ability of the owner/operator to receive a text message for critical alarms.
- 18. Shall have the ability to access the PLC via downloadable app. Functionality shall be identical to PLC interface.

F. PUMP MANIFOLD

- 1. Shall be constructed of AISI 304 Stainless steel.
- 2. All pump connections shall be 300 Class ANSI flanges.
- 3. System connection flanges shall either be ANSI 150 Class or 300 Class flanges depending on system pressure.
- 4. All manifolds shall be electrolytic polished.
- 5. All manifolds shall be 10S and rated for 363 PSI maximum pressure.
- Manifold shall have two, ¼" FNPT shut off valves; one connected to an analog dial pressure gauge and one connected to a pressure transducer.
- 7. Discharge manifold shall have a ¾" connection with plugged shut off valve.

G. ISOLATION VALVES

- 1. Shall be constructed using ASTM 304 Stainless steel.
- 2. All threads shall be female, nominal tapered threads in accordance with ANSI B1.20.1.
- 3. Packing, thrust washer, and gasket, shall all be constructed of PTFE.
- 4. Seat shall be constructed of PTRE.

H. CHECK VALVE

- Every pump, in relation to the pump manifold, shall have a 316 Stainless Steel ASTM A240 check valve in either an NPT or Victaulic connection; depending on booster size and model.
- 2. Check valve shall be a "flapper-style", non-slam, check valve.
- 3. Elastomer seal for check valve shall be made of Buna N.

I. OPTIONAL COMPONENTS 1

- 1. (Hydropneumatic Tank Option).
 - a. Shall be a 2.1 gallon capacity.
 - b. Shall be rated for 232 PSI.
 - c. Shall be Non-ASME rated.
 - d. Shall be only rated to prevent short cycling of the pump package and provide water hammer protection.
 - e. Tanks for system capacity and ASME-rated tanks shall also be available upon request.
- 2. (ODP motors available in lieu of TEFC upon request (but not recommended)).
- 3. (NEMA 3R Control panel enclosure).
- (Dome tower light; options for Green (Run
 –System good), Yellow (Fault Still
 running), Red (Failure Not running) and
 White (Power Present)).
- 5. (Run/Fault LED lights, per Pump, mounted on front of panel).
- 6. (BMS Protocol Options):
 - a.(BacNET)
 - b.(LonWorks)
- 7. (Booster packages available at higher pressures upon request).

PART 3 EXECUTION

3.01 INSTALLATION

- A. Install equipment in accordance with manufacturer's instructions.
- B. Power wiring, as required, shall be the responsibility of the electrical contractor. All wiring shall be performed per manufacturer's instructions and applicable state, federal and local codes.

Division 22 – PLUMBING 22 11 23.13 – DOMESTIC-WATER PACKAGED BOOSTER PUMPS

- C. All factory wiring shall be numbered for easy identification and the numbers shall coincide with those shown on the wiring diagram.
- D. Unit shall be a Wilo- SiBooster EXCEL as manufactured by Wilo USA.

END OF SECTION

¹ Components in parenthesis indicate an optional item.

Wilo USA 888-945-6872 www.wilo-usa.com Wilo Canada Inc. 866–945–6236 www.wilo-canada.com Wilo Mexico +52 442 167 00 32 www.wilo-mexico.com

