

Checklist for MBBR-Applications.

Activation-, N-, DN-tanks.

Data and basic conditions

Waste water properties		Municipal Industry	Installation		New construction Refitting		
Dry solids content		%	Calculation relevant filling level m				
Sludge volume index		ml/g	Calculation relevant tank volume m³				
Density		kg/m³	Tank geometry, inflows and outflows				
Temperature		°C	acc. to drawing/sketch				
pH-value			Tank material		Concrete Steel		
Type designation and size of the carriers			Mixer operation		h/year		
Density of the carriers		kg/m³	Energy costs		€/kWh		
Percentage of carriers		%	Selection procedure		Energy optimized Invest optimized		
Aeration							
No			Type of ground aeration				
Yes, simultaneous		Surface covered	_				
Yes, but discontinuou		by aeration	m ²				
Duration of aeration	-	h/d	Distance tank ground top edge of aerators	m			
Aeration intervals		d	Number of aeration f	ields			
Air quantity under standar conditions	rd		at distances betweer fields > 2 m	pcs			
min.		m³/s					
normalm³/s							
max.		m³/s					

Stand: 02/2013 1



Technical Data

Voltage		V	Temperature contro	l	☐ Bimetal sensor
Frequency		50 Hz 60 Hz			☐ Cold type thermistors (PTC)
Ex-Approval Type of starting		Yes	Leakage control		
		No	Length of power cab	ole	m
		Direct Frequency transformer Soft starting	Corrosion protection		2 component polymer coating (Ceram CO)
		Star delta			2 component high solid coating

Sketch:

Please send the completely filled checklist to:

WILO SE, Werk Hof
Group Competence Team Wastewater Treatment
Heimgartenstraße 1-3, 95030 Hof/Saale, T +49 (0)9281 974-540, ctwwt@wilo.com

Project-/Request number:

Company:

Name:

Phone:

Phone:

E-Mail:

Stand: 01/2013 2