



Wilo IL In-Line Centrifugal Hydronic Pumps

**Engineering Specification** 

# **PART 1 GENERAL**

### 1.01 SUMMARY

- A. Pump shall be Cronoline IL, split-coupled, single stage vertical inline centrifugal pump as manufactured by WILO USA LLC.
- B. Furnish and install extended life, low-maintenance pumps with capacities as shown on plans/submittals.

# **1.02 REFERENCES**

- A. ANSI American National Standards Institute
- B. EISA 2007 Energy Independence and Security Act of 2007
- C. NEMA National Electrical Manufacturers Association
- D. HI Hydraulic Institute

# **1.05 SUBMITTALS**

- A. Performance curve
- B. Power curve
- C. NPSH curve
- D. Materials of construction
- E. Operating limits

# **1.06 QUALITY ASSURANCE**

- A. Shall be factory tested per Hydraulic Institute (HI) standards prior to shipment
- B. Shall conform to HI 1.1-1.2, and 1.3 for recommended acceptable unfiltered field vibration limits.

# 1.07 DELIVERY, STORAGE, AND HANDLING

- A. In preparation for shipping, the pump shall have clean flanges and any exposed machined metal surfaces will be cataphoretically coated.
- B. Protection of the flanges, pipe openings, and nozzles shall be supplied with wooden or plastic flange covers or with screwed-in plugs.

# PART 2 PRODUCT

#### 2.01 MANUFACTURERS

- A. Subject to compliance with the specifications, the following manufacturers shall be acceptable:
  - 1. WILO USA LLC
  - 2. Pre-approved equal.

# 2.05 EQUIPMENT

- A. Shall be factory assembled and tested, centrifugal, impeller mounted on stub shaft, split-coupled, single-suction pump as defined in HI Standard 40.6.
- B. Shall be designed for base mounting, with pump and motor shafts vertical or horizontal. (Note: Horizontal motor shaft mounting allowable up to 3 Horsepower without support).
- C. Shall be rated for 175-psi (12 bar) maximum working pressure and a continuous water temperature of 248°F (120°C).
- D. Shall be designed with an integral suction straightening vane (in select models).
- E. Glycols min 20% up to max 50% volumetric, up to 248°F (120°C).

# 2.06 COMPONENTS

- A. Pump Casing
  - 1. Shall be constructed of cast iron EN-GJL-250, ASTM equivalent ASTM A48 Class 40B.
  - 2. Shall have threaded gauge tappings at inlet and outlet.
  - 3. Shall have an air vent at top of volute.
  - 4. Shall have flanges compatible with 125 lb. ANSI.
  - 5. Pump Volute shall be sealed via an EPDM Oring.
  - 6. Cast pump feet shall be drilled and tapped for ease of installation onto base pad if necessary.
  - 7. Cataphoretic coating shall be applied electrostatically to prevent corrosion.

- B. PUMP COVER / MOTOR STOOL
  - 1. Shall be constructed of cast iron (ASTM A48 Class 40B).
  - Shall be drilled and tapped to accommodate a mechanical seal flush line which can be connected to the corresponding discharge connection to facilitate cooling and flushing of the mechanical seal.
  - Motor stool/pump cover interface shall be sealed by an O-ring and shall include extra tappings for removal from pump volute by using "jack screws".
- C. IMPELLER
  - 1. Shall be constructed of bronze (G-CuSn10).
  - 2. Shall be statically and dynamically balanced and keyed to shaft.
  - 3. The allowable residual unbalance in the impeller rotating assembly shall conform to ANSI Grade G6.3.
  - 4. The diameter shall be trimmed to match the specified performance.

# D. STUB SHAFT

- 1. Shall be constructed of 316L Stainless Steel.
- E. MECHANICAL SEAL
  - 1. Shall be an internally flushed mechanical seal with silicon carbide seal faces.
  - 2. Shall have HNBR elastomers.
  - 3. Shall have a stainless steel spring.
- F. SPLIT COUPLING
  - 1. Shall be an axially-split device capable of absorbing torsional vibration.

- 2. Shall be employed between the pump stub and motor shafts.
- G. COUPLING GUARD
  - 1. Shall be ANSI B15.1.
  - Shall be a Section 8 & OSHA 1910.219 compliant coupling guard which contains viewing windows for inspection of the coupling mounted to the pump end.
- H. MOTOR
  - 1. Shall be single speed.
  - 2. Motor bearings shall be sealed and permanently greased.
  - 3. Shall have a secured mounting motor stool.
  - 4. Shall meet EISA 2007 requirements and NEMA MG1 Table 12-12 specifications.
  - 5. Shall be the size, voltage, and enclosure called for on the plans.

# PART 3 EXECUTION

# **3.05 INSTALLATION**

- A. Complete installation and startup checks in accordance to manufacturer's instructions.
- B. Check piping connections for tightness. Pipe connections to pumps shall be made in such a manner so as not to exert any stress on the pump housing.
- C. Clean strainers on suction piping.

END OF SECTION