



产品认证证书

中国节能认证

证书编号: CQC13701104057

发证日期: 2023 年 12 月 01 日
有效期至: 2025 年 11 月 06 日

委托人名称 威乐 (中国) 水泵系统有限公司
及注册地址 北京市顺义区兆丰二街 10 号院 1 幢 1 层 103
品牌 威乐

制造商名称 威乐 (中国) 水泵系统有限公司
及注册地址 北京市顺义区兆丰二街 10 号院 1 幢 1 层 103

生产企业名称 威乐 (中国) 水泵系统有限公司
及生产地址 北京市顺义区空港工业区 C 区兆丰二街 10 号

产品名称和系列、规格、型号 SCP/SCPC 系列单级双吸清水离心泵
SCP/SCPC 系列 具体型号规格见附件

产品标准和技术要求 GB 19762-2007

认证模式 产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC31-432212-2009 认证规则的要求, 特此发证。
本证书为变更证书, 证书首次颁发日期: 2013 年 12 月 31 日
证书有效期内本证书的有效性依据发证机构的定期监督获得保持。
经中国合格评定国家认可委员会认可 CNAS C001-P

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



签发:

谢肇煦



中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

JC 0256715



CERTIFICATE OF PRODUCT CERTIFICATION

CHINA CERTIFICATE FOR ENERGY CONSERVATION PRODUCT

CERTIFICATE NO.: CQC13701104057

Valid from: Dec.01,2023

Valid until: Nov.06,2025

NAME AND REGISTERED ADDRESS OF THE APPLICANT	WILO CHINA LTD Room 103, 1st Floor, Building 1, Block 10, second Zhaofeng Street, Shunyi District, Beijing.
BRAND NAME	WILO
NAME AND REGISTERED ADDRESS OF THE MANUFACTURER	WILO CHINA LTD Room 103, 1st Floor, Building 1, Block 10, second Zhaofeng Street, Shunyi District, Beijing.
NAME AND LOCATION OF THE FACTORY	WILO CHINA LTD No.10 Zhao Feng 2nd Str., Zhao Feng Ind.Zone, ZhaoQuanYing, ShunYi, Beijing, China 101300
PRODUCT NAME, MODEL AND SPECIFICATION	SCP/SCPC Series single stage double-suction centrifugal pump See appendix
THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS	GB 19762-2007
TYPE OF CERTIFICATION SCHEMES	Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of CQC31-432212-2009.

Date of original issued: Dec.31,2013

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦

CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R. China

Tel: +86 10 83886666

JC 0256715



产品认证证书

中国节能认证

证书编号: CQC13701104057

第 1 页 / 共 9 页


本证书及附件应同时使用, 信息查验说明见证书页

纸号: 256715

序号	泵型号	流 量 (m ³ /h)	扬程 (m)	比转速	电机功 率 (kW)	临界汽 蚀余量 (m)	泵效率 (%)	节能评 价值(%)
1	SCP125/330HA-22/4	171.3	25.5	71.9	22	3	78.30%	77.70%
2	SCP125/330HA-22/4	187.7	24.5	77.5	22	3.4	79.20%	79.00%
3	SCP125/330HA-30/4	148.6	34.9	52.9	30	2.9	74.50%	72.10%
4	SCP125/330HA-30/4	173.6	32.5	60.4	30	3.1	79.20%	74.90%
5	SCP125/330HA-30/4	199.1	26.9	74.4	30	3.4	79.90%	78.70%
6	SCP125/330HA-30/4	204.4	30.6	68.5	30	2.8	80.80%	77.50%
7	SCP125/330HA-30/4	205.9	28.3	72.9	30	2.5	80.20%	78.50%
8	SCP125/330HA-30/4	214.4	31.6	68.5	30	2.8	80.90%	77.70%
9	SCP 125/330 HA-30/4	230	35.5	66.4	30	2.7	83.00%	77.44%
10	SCP125/330HA-37/4	119.9	38.8	44	37	2.3	69.40%	67.80%
11	SCP125/330HA-37/4	150.1	39.9	48.2	37	2.4	76.20%	70.60%
12	SCP125/330HA-37/4	197.9	37.3	58.1	37	2.6	81.70%	74.70%
13	SCP125/330HA-37/4	230	35.4	65.2	37	2.7	83.20%	77.10%
14	SCP125/330HA-37/4	230.3	34.6	66.3	37	2.7	82.30%	77.30%
15	SCP125/330HA-37/4	250	34.8	68.8	37	2.8	81.70%	78.20%
16	SCP150/390HA-55/4	299.8	37.8	70.9	55	2.8	80.10%	79.20%
17	SCP150/440HA-110/4	294.1	62.7	48	110	2.5	73.70%	72.60%



中国质量认证中心





产品认证证书

中国节能认证

证书编号: CQC13701104057

第 2 页 / 共 9 页


本证书及附件应同时使用, 信息查验说明见证书页

纸号: 256715

序号	泵型号	流 量 (m ³ /h)	扬程 (m)	比转速	电机功 率 (kW)	临界汽 蚀余量 (m)	泵效率 (%)	节能评 价值(%)
18	SCP150/440HA-75/4	252.4	52.7	50.7	75	2.4	73.70%	73.10%
19	SCP150/440HA-75/4	295.5	47.3	59.5	75	2.8	76.80%	76.30%
20	SCP150/440HA-75/4	296.9	50	57.2	75	3	76.80%	75.70%
21	SCP150/440HA-90/4	250	61.9	44.7	90	2.8	73.20%	70.80%
22	SCP150/350HA-37/4	347.1	27.7	96.2	37	3.4	83.60%	83.10%
23	SCP150/350HA-45/4	349.3	33.2	84.3	45	3.3	83.30%	81.90%
24	SCP150/350HA-45/4	399	31	94.8	45	3.8	85.10%	83.50%
25	SCP150/350HA-45/4	392	27.8	102	45	3.7	84.50%	83.90%
26	SCP150/350HA-55/4	347.9	37.3	77.1	55	3.7	84.00%	80.90%
27	SCP150/350HA-55/4	396.8	35.1	86.1	55	3.8	85.50%	82.60%
28	SCP150/350HA-55/4	452.7	32.3	97.9	55	4.2	85.10%	84.10%
29	SCP150/350HA-75/4	314.1	42.7	66.1	75	3.4	78.40%	78.30%
30	SCP150/350HA-75/4	393.4	39.7	78.3	75	3.6	84.20%	81.50%
31	SCP150/350HA-75/4	452.1	36.9	88.6	75	3.7	84.80%	83.30%
32	SCP150/390HA-55/4	322.6	35.1	77.7	55	3	81.10%	80.70%
33	SCP150/390HA-55/4	351.5	35.4	80.6	55	3.2	81.80%	81.50%
34	SCP150/390HA-55/4	343.9	33.9	82.3	55	3.3	81.70%	81.60%



中国质量认证中心





产品认证证书

中国节能认证

证书编号：CQC13701104057

第3页 /共9页


本证书及附件应同时使用，信息查验说明见证书页

纸号：256715

序号	泵型号	流 量 (m ³ /h)	扬程 (m)	比转速	电机功 率 (kW)	临界汽 蚀余量 (m)	泵效率 (%)	节能评 价值(%)
35	SCP150/390HA-55/4	369.6	34.3	84.6	55	3.6	82.30%	82.20%
36	SCP150/390HA-75/4	303.8	51.6	56.5	75	2.8	80.30%	75.50%
37	SCP150/390HA-75/4	349.6	49.6	62.4	75	3	82.60%	77.70%
38	SCP150/390HA-75/4	401	47.3	69.3	75	3.4	83.90%	79.90%
39	SCP150/390HA-75/4	371.6	43.5	71	75	3.2	83.70%	80.00%
40	SCP150/390HA-75/4	377.8	43.2	71.9	75	3.3	83.90%	80.20%
41	SCP150/390HA-75/4	397.4	42	75.3	75	3.6	83.80%	81.00%
42	SCP150/390HA-75/4	420.7	40.5	79.6	75	3.6	83.50%	81.90%
43	SCP150/440HA-110/4	345.7	63.5	51.6	110	2.7	79.40%	74.40%
44	SCP150/440HA-110/4	392.7	60.4	57.1	110	3	80.40%	76.60%
45	SCP150/440HA-110/4	392.4	58	58.8	110	3.1	78.90%	77.10%
46	SCP150/440HA-110/4	393	57.8	59	110	3.2	78.60%	77.20%
47	SCP150/440HA-110/4	421.3	55.7	62.8	110	3.8	78.70%	78.40%
48	SCP150/440HA-75/4	357.9	49.7	63	75	3.5	79.50%	77.90%
49	SCP150/440HA-90/4	300.5	58	51.4	90	3	77.70%	73.90%
50	SCP150/440HA-90/4	344.9	55.3	57.1	90	3.3	79.50%	76.20%
51	SCP150/440HA-90/4	392.9	51.6	64.2	90	3.4	79.90%	78.60%



中国质量认证中心





产品认证证书

中国节能认证

证书编号: CQC13701104057

第 4 页 / 共 9 页


本证书及附件应同时使用, 信息查验说明见证书页

纸号: 256715

序号	泵型号	流 量 (m ³ /h)	扬程 (m)	比转速	电机功 率 (kW)	临界汽 蚀余量 (m)	泵效率 (%)	节能评 价值(%)
52	SCP150/440HA-90/4	403	50.8	65.8	90	3.3	80.30%	79.10%
53	SCP200/310HA-37/4	400.3	23	119	37	4	85.20%	85.00%
54	SCP200/310HA-45/4	446	26.5	112.7	45	3.7	85.30%	85.10%
55	SCP200/360HB-90/4	594.9	40.1	95.5	90	4.3	85.40%	84.70%
56	SCP200/440HA-132/4	403.3	56.1	61.1	132	6.2	79.30%	77.90%
57	SCP200/440HA-132/4	550.4	52.6	74.9	132	7.2	86.10%	81.90%
58	SCP200/440HA-160/4	401.6	66.9	53.4	160	6.4	78.20%	75.60%
59	SCP200/440HA-160/4	545.6	62.2	65.8	160	6.1	83.90%	80.00%
60	SCP200/440HA-90/4	392.2	48.3	67.4	90	6	80.00%	79.40%
61	SCP200/440HA-90/4	497.2	43.8	81.6	90	6.5	84.30%	82.80%
62	SCP200/440HA-90/4	547.9	41.9	88.6	90	7.4	84.70%	83.80%
63	SCP200/440HA-90/4	568	41.3	91.3	90	8	85.30%	84.20%
64	SCP200/440HA-90/4	591.6	42.1	91.8	90	8.2	86.40%	84.40%
65	SCP200/310HA-45/4	452.9	24.6	120.2	45	3.7	85.60%	85.40%
66	SCP200/320HA-37/4	521.3	20.2	149.5	37	4.5	86.60%	85.80%
67	SCP200/320HA-37/4	545.7	19.5	157	37	4.6	86.60%	85.90%
68	SCP200/320HA-37/4	558.8	19.3	160.2	37	4.7	86.60%	86.00%



中国质量认证中心





产品认证证书

中国节能认证

证书编号：CQC13701104057

第 5 页 / 共 9 页


本证书及附件应同时使用，信息查验说明见证书页

纸号：256715

序号	泵型号	流 量 (m ³ /h)	扬程 (m)	比转速	电机功 率 (kW)	临界汽 蚀余量 (m)	泵效率 (%)	节能评 价值(%)
69	SCP200/320HA-37/4	566	19.2	161.6	37	4.8	86.90%	86.00%
70	SCP200/320HA-37/4	568.6	18.8	164.7	37	4.8	86.40%	86.00%
71	SCP200/320HA-45/4	519.6	23.4	133.4	45	4.4	85.80%	85.80%
72	SCP200/320HA-45/4	598.7	22.1	149.6	45	4.6	87.80%	86.20%
73	SCP200/320HA-45/4	589.2	21.8	149.9	45	4.7	87.50%	86.10%
74	SCP200/320HA-55/4	572.2	26	129.8	55	4.6	87.00%	86.10%
75	SCP200/320HA-75/4	595.9	28.7	122.8	75	4.7	86.40%	86.20%
76	SCP200/360HB-75/4	641.4	33.4	113.7	75	3.8	87%	85%
77	SCP200/360HB-90/4	655.9	38.5	103.4	90	3.9	87%	85%
78	SCP200/360HB-90/4	700.8	37.2	109.7	90	4.1	88%	85%
79	SCP200/360HB-90/4	745.2	35.8	116.3	90	4.4	88%	86%
80	SCP200/390HA-110/4	609.6	44.1	90	110	4.1	85%	83%
81	SCP200/390HA-110/4	692.6	40.7	101.9	110	4.7	86%	85%
82	SCP200/390HA-110/4	710.6	41.2	102.2	110	5	87%	85%
83	SCP200/390HA-110/4	745.5	40	107	110	5.2	86%	85%
84	SCP200/390HA-132/4	601.4	49.5	82	132	3.9	83%	82%
85	SCP200/390HA-132/4	696.4	47	91.8	132	4.6	86%	84%



中国质量认证中心





产品认证证书

中国节能认证

证书编号: CQC13701104057

第 6 页 / 共 9 页

本证书及附件应同时使用, 信息查验说明见证书页

纸号: 256715

序号	泵型号	流 量 (m ³ /h)	扬程 (m)	比转速	电机功 率 (kW)	临界汽 蚀余量 (m)	泵效率 (%)	节能评 价值(%)
86	SCP200/390HA-132/4	747.8	46.1	96.4	132	5.2	87%	84%
87	SCP200/390HA-132/4	747.7	45.3	97.7	132	5.2	87%	85%
88	SCP200/390HA-132/4	757.3	45	98.9	132	5.3	87%	85%
89	SCP200/390HA-132/4	799.8	43.3	104.5	132	5.8	86%	85%
90	SCP200/390HA-75/4	632.8	33.4	112.8	75	4.2	85%	85%
91	SCP200/390HA-90/4	613	39.3	98.5	90	4.1	85%	84%
92	SCP200/390HA-90/4	674	37.5	106.9	90	4.4	86%	85%
93	SCP200/390HA-90/4	694.4	36.8	110	90	4.7	86%	85%
94	SCP200/440HA-132/4	653.2	49	86.1	132	5.9	87%	83%
95	SCP200/440HA-132/4	649.2	47.6	87.7	132	5.3	85%	83%
96	SCP200/440HA-132/4	672.6	46.4	91	132	5.5	85%	84%
97	SCP200/440HA-160/4	647.5	58.7	74.8	160	5.2	86%	81%
98	SCP200/440HA-160/4	705.3	58.8	78	160	5.4	89%	82%
99	SCP200/440HA-160/4	795.4	51.9	91	160	5.8	85%	84%
100	SCP200/440HA-90/4	669.2	39.1	103.2	90	5.3	86%	85%
101	SCP250/450HA-200/4	997.7	49.3	105.8	200	6.2	87%	86%
102	SCP250/450HA-200/4	1083.7	49	110.9	200	6.5	87%	86%



中国质量认证中心





产品认证证书

中国节能认证

证书编号：CQC13701104057

第 7 页 / 共 9 页


本证书及附件应同时使用，信息查验说明见证书页

纸号：256715

序号	泵型号	流 量 (m ³ /h)	扬程 (m)	比转速	电机功 率 (kW)	临界汽 蚀余量 (m)	泵效率 (%)	节能评 价值(%)
103	SCP250/450HA-200/4	1080.7	47.5	113.4	200	6.3	88%	87%
104	SCP250/450HA-220/4	1083.2	51.5	106.7	220	6.4	88%	86%
105	SCP250/450HA-220/4	1162.4	49.7	113.7	220	6.6	88%	87%
106	SCP250/450HA-220/4	1208.8	50.7	114.1	220	6.8	88%	87%
107	SCP250/450HA-220/4	1187.9	48.7	116.6	220	6.7	88%	87%
108	SCP250/450HA-280/4	985.4	65.8	84.8	280	6.3	86%	84%
109	SCP250/450HA-280/4	1191.8	59.7	100.2	280	6.7	90%	86%
110	SCP250/450HA-280/4	1284.2	56.9	107.8	280	6.9	89%	87%
111	SCP250/570HA-400/4	1000.2	83.4	71.5	400	4.9	84%	82%
112	SCP250/570HA-400/4	1090.2	81.1	76.2	400	5.2	85%	83%
113	SCP250/570HA-400/4	1196.8	78.4	81.9	400	6.2	85%	84%
114	SCP250/570HA-400/4	1293.1	75.8	87.3	400	7.3	86%	85%
115	SCP250/570HA-500/4	1005.3	97.9	63.6	500	5	84%	80%
116	SCP250/570HA-500/4	1200.2	95.8	70.6	500	6.3	85%	82%
117	SCP250/570HA-500/4	1393.8	90.1	79.6	500	7.8	85%	84%
118	SCP250/570HA-560/4	791.2	117.1	49.3	560	4.4	75%	75%
119	SCP250/570HA-560/4	1087	110.4	60.4	560	5.4	85%	79%



中国质量认证中心





产品认证证书

中国节能认证

证书编号: CQC13701104057

第 8 页 / 共 9 页


本证书及附件应同时使用, 信息查验说明见证书页

纸号: 256715

序号	泵型号	流 量 (m ³ /h)	扬程 (m)	比转速	电机功 率 (kW)	临界汽 蚀余量 (m)	泵效率 (%)	节能评 价值(%)
120	SCP250/570HA-560/4	1288	104.9	68.3	560	6.8	86%	82%
121	SCP250/570HA-560/4	1487	97.7	77.4	560	8.5	86%	84%
122	SCP400/660DV-1120/4	2003.6	133.1	71.2	1120	7.6	85%	83%
123	SCP400/660DV-1120/4	2424.9	121.9	83.7	1120	7.5	88%	86%
124	SCP400/660DV-1120/4	2634.5	115.2	91	1120	7.9	89%	87%
125	SCP400/660DV-900/4	2003.4	115.2	79.4	900	7.4	85%	85%
126	SCP400/660DV-900/4	2412.6	108.6	91.1	900	7.8	87%	87%
127	SCP400/660DV-900/4	2609.5	103.3	98.3	900	8	88%	87%
128	SCP200/320HA-45/4	646	20.7	163.4	45	5.3	87%	85%
129	SCP200/320HA-55/4	644.7	24.3	144.7	55	5.1	89%	85%
130	SCP200/320HA-55/4	693.5	22.8	157.5	55	5.2	88%	86%
131	SCP200/320HA-75/4	645.8	27.6	131.5	75	4.6	88%	85%
132	SCP200/320HA-75/4	695.8	26.4	141.1	75	4.8	88%	86%
133	SCP200/320HA-75/4	744.9	26.4	146.3	75	5	88%	86%
134	SCP200/320HA-75/4	792	23.3	165.5	75	5.6	86%	86%
135	SCP200/360HB-75/4	691.6	31.9	122.3	75	4.1	87%	86%
136	SCP200/360HB-75/4	644.9	29.1	126.5	75	3.9	86%	85%



中国质量认证中心





产品认证证书

中国节能认证

证书编号: CQC13701104057

第 9 页 / 共 9 页

本证书及附件应同时使用, 信息查验说明见证书页

纸号: 256715

序号	泵型号	流 量 (m ³ /h)	扬程 (m)	比转速	电机功 率 (kW)	临界汽 蚀余量 (m)	泵效率 (%)	节能评 价值(%)
137	SCP200/360HB-75/4	745.9	30	132.8	75	4.6	86%	86%
138	SCP200/360HB-90/4	795	34.1	124.5	90	5.2	87%	86%
139	SCP250/450HA-200/4	1192.4	44.2	125.7	200	6.8	87%	87%
140	SCP250/450HA-220/4	1287.6	48.5	121.7	220	7.1	87%	87%
141	SCP400/540HB-220/6	2326.5	24.5	179	220	6.5	89%	88%
142	SCP400/540HB-220/6	2466.3	23.4	190.9	220	6.7	90%	89%
143	SCP400/540HB-220/6	2583.5	22.5	201	220	6.9	90%	89%
144	SCP400/540HB-250/6	2467.5	29.8	159	250	6.7	91%	89%
145	SCP400/540HB-250/6	2631	29.2	167.1	250	7	90%	89%
146	SCP400/540HB-250/6	2590.3	28.7	167.5	250	6.7	91%	89%
147	SCP400/540HB-250/6	2711.9	27.9	175.5	250	7.1	91%	89%
148	SCP400/540HB-315/6	2460.6	34.7	141.7	315	6.5	90%	89%
149	SCP400/540HB-315/6	2660.8	33.7	150.6	315	6.7	90%	89%
150	SCP400/540HB-315/6	2709.5	32.8	155.3	315	7	91%	89%



中国质量认证中心

