



# 产品认证证书

证书编号: CQC17018173371

发证日期: 2021年06月28日

有效期至: 2025年06月28日

**委托人名称** 威乐(中国)水泵系统有限公司  
**及注册地址** 北京市顺义区兆丰二街10号院1幢1层103

**制造商名称** 威乐(中国)水泵系统有限公司  
**及注册地址** 北京市顺义区兆丰二街10号院1幢1层103

**生产企业名称** 威乐(中国)水泵系统有限公司  
**及生产地址** 北京市顺义区空港工业区C区兆丰二街10号

**产品名称和系列、规格、型号** 不锈钢卧式多级离心泵  
见附件

**产品标准和技术要求** GB 10395.8-2006

**认证模式** 产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC11-432211-2009 认证规则的要求, 特发此证。  
本证书为变更证书, 证书首次颁发日期: 2017年07月04日  
证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站 ([www.cnca.gov.cn](http://www.cnca.gov.cn)) 查验证书信息



签发: 谢肇煦



中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

C 0501145





# CERTIFICATE OF PRODUCT CERTIFICATION

CERTIFICATE NO.: CQC17018173371

Valid from: Jun.28,2021

Valid until: Jun.28,2025

<b>NAME AND REGISTERED ADDRESS OF THE APPLICANT</b>	WILO CHINA LTD. Room 103, 1st Floor, Building 1, Block 10, second Zhaofeng Street, Shunyi District, Beijing
<b>NAME AND REGISTERED ADDRESS OF THE MANUFACTURER</b>	WILO CHINA LTD. Room 103, 1st Floor, Building 1, Block 10, second Zhaofeng Street, Shunyi District, Beijing
<b>NAME AND LOCATION OF THE FACTORY</b>	WILO CHINA LTD. No.10 Zhao Feng 2nd Str., Zhao Feng Ind.Zone, ZhaoQuanYing, ShunYi, Beijing, China 101300
<b>PRODUCT NAME, MODEL AND SPECIFICATION</b>	MHI Small multistage centrifugal pump See Appendix
<b>THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS</b>	GB 10395.8-2006
<b>TYPE OF CERTIFICATION SCHEMES</b>	Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-432211-2009.

Date of original issued: Jul.04,2017

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



SIGNATURE:

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86 10 83886666

C 0501145





# 产品认证证书

证书编号: CQC17018173371

第 1 页 共 1 页

本证书及附件应同时使用, 信息查验说明见证书页

纸号: 501145

序号	型号规格	额定流量 (m <sup>3</sup> /h)	额定扬程 (m)	额定转速 (r/min)	机组效率 (%)	进口口径 (mm)	出口口径 (mm)
1	MHI201-1/10/E/1-220-50-2	2	9.5	2800	27.7	Φ33.2	Φ33.2
2	MHI202-1/10/E/1-220-50-2	2	19	2700	28.1	Φ33.2	Φ33.2
3	MHI203-1/10/E/1-220-50-2	2	28	2700	30.1	Φ33.2	Φ33.2
4	MHI204-1/10/E/1-220-50-2	2	36	2700	29.4	Φ33.2	Φ33.2
5	MHI205-1/10/E/1-220-50-2	2	46	2720	30.2	Φ33.2	Φ33.2
6	MHI206-1/10/E/1-220-50-2	2	58.6	2800	30.0	Φ33.2	Φ33.2

备注: 序号 4 型号参数中额定转速从 2720 r/min 变更为 2700r/min, 序号 5 型号参数中的转速从 2800 r/min 变更为 2720r/min。



中国质量认证中心

