

Directory Search Results

#1910071

Approved Product

Range of booster sets incorporating pumps, expansion vessels, Isolation valves and non-return valves (not suitable for backflow protection). Maximum working pressures: SI boost 16.0 bar, CO R 10.0 bar. Cold water use only.

Section: 1610 Pumps (?section=1610)

Section Subtitle: Wholesome water use.

WRAS Approval Number: 1910071

Expiry date: 31/10/2024

Size: DN100, DN125, DN150 & DN200 flange. 1½", 2", 2 ½" & 3" BSP.

Marking: Wilo logo, model name, maximum temperature and PN rating on adhesive label on body.

Installation Requirements: R001 (/approvals/testing-requirements/installation_requirements/irn_r001)R415 (/approvals/testing-requirements/installation_requirements/irn_r415)

Model: COR 2-3MHI UKe-EM, COR 2-3MHIE UKe-DM, COR 2-4 HELIX VE, COR 2-4 HELIX V & COR 2-4 EXCEL RANGES OF BOOSTER SETS

Factor: Wilo UK

[View All Listings by this Company \(?company=13712\)](#)